

**MIDLAND COUNTY**

**220 W. Ellsworth  
Midland, MI 48640**

**Backbone Fiber Network –  
Pinecrest Farms Care Facility**

***Request For Proposal*  
Addendum #1 – *Final Addendum*  
07-22-10**

**Issue Date: 06/24/10**

**Due Date: 08/03/10 1:00 PM**

**Midland County  
Educational Service  
Agency Building**

**Question Deadline: 07/22/10, 12:00 PM**

**Prepared by  
CHILDS CONSULTING ASSOCIATES, INC.  
707 N. Huron Avenue, P. O. Box 550,  
Mackinaw City, MI 49701  
231-436-4099 • 231-436-4101 FAX [www.childs.com](http://www.childs.com)  
©2010**

This addendum is issued prior to the award of a contract for the M.Co.Net Backbone Fiber Network Extension to Pinecrest Farms Care Facility RFP (Midland, Michigan). The items listed below are for clarification to the RFP (dated 06-24-10). This addendum shall supersede those parts from which it differs.

**OVERALL COMMENTS AND ADDITIONS**

In this addendum we respond to questions from vendors. The questions and responses are primarily for clarification.

**VENDOR QUESTIONS** – Following is the single question received subsequent to the issuance of the RFP, dated 06/24/10, and prior to the deadline for questions:

Question: Are the 3” and 4” conduits to be filled with a combination of innerduct cells as part of our bids? If so, what configuration of innerduct cells are required for each conduit size?

Answer: *No innerduct will be installed in the 3 or 4 inch conduit with the fiber.*

[END OF ADDENDUM 1 – FINAL ADDENDUM]

**This form must be signed and submitted with the bid forms by the bid due date.**

**This acknowledges the receipt and acceptance of all items and issues contained in “Addendum 1”.**

**Signed** \_\_\_\_\_

**Print Name** \_\_\_\_\_

**Company** \_\_\_\_\_